



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

## Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

### Division of Facilities Construction and Management

F. KEITH STEPAN  
Director

# ADDENDUM

Date: 13 April 2007

To: Contractors

From: Rick James, DFCM

Reference: Post Academy Remodel - Design  
Division of Homeland Security – Department of Public Safety  
DFCM Project No.07030550

Subject: **Addendum No. 1**

Addendum	1 page
<u>Drawings</u>	<u>3 pages</u>
<b>Total</b>	<b>4 pages</b>

---

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in this Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.*

#### **SCHEDULE CHANGES – There are no project schedule changes per this Addendum.**

There are no changes to the schedule of this selection with the exception that this addendum is being issued on Friday, April 13, 2007 instead of Wednesday, April 11, 2007.

#### **1.1 GENERAL**

- 1.1.1 Question: What is the desired seismic resistance level for the building after construction?  
Answer: *The building should be design to meet the requirements of an essential facility and the “Immediate Occupational Level”.*
- 1.1.2 Attached to this addendum are three drawings in pdf format of the floor plans of the Post Building for your information.

End of Addendum No. 1





